



Information contained herein is based upon the report 'Achieving Water Independence In Buildings' by 'Central City Concern' of Portland, Oregon and represents the opinion of cited contributors regarding water re-use regulations in California as of the date indicated. No guarantee as to the accuracy of this information is provided or implied. As always, consult a licensed professional as well as State, regional and local authorities-having-jurisdiction prior to commencing work of any kind related to or informed by this document. Comments to facilitate continuous improvement? E-mail: kkingston@archnexus.com or jdavis@archnexus.com

Rain Water
 Quality: CPC (2016) K101.5
 Storage: NSF/ANSI 61
 Operations: CA Title 22; 64413.1, 64423, 64449
 Operations: CA Title 17 65654
 Operations: EPA LT2ESWTR
 CA Safe Drinking Water Act 116275
 CWS: Community Water System (public system)
 NWS: Noncommunity Water System (<25 people)
 NNWS: Nontransient Noncommunity Water System (25+ People)
 DDW: Division of Drinking Water of the California Water Resources Control Board

